

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. - 84

Dated: 10-04-2026

It is certified that an inspection team headed by

Er. Desh Raj Pathak (A.E)

(Name of Officers with designation) from

Jal Shakti Vibhag

(Name of Department/ Office) inspected the

Sai Ram International School mangyunt


(Name & Address of the school) on 07-04-2026 (date of inspection) and found that the

Sai Ram International school (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of

07-04-2026 to 06-04-2027

Signature with Seal:



Name:

Desh Raj Pathak

Designation:

Assistant Engineer.

Name & Address of the Office / Department:

Assistant Engineer
Jal Shakti Sub-Division
Nalagarh

To

Sai Ram International school

P.O. Rajpura Tehsil Nalagarh
Dist. Salas (H.P.)

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

WATER TESTING LABORATORY NALAGARH

JSV SUB -DIVISION: NALAGARH

DISTRICT : SOLAN

Lab Ref No

Based Upon BIS : 10500-2012

Date 10-04-2026

Name and Address of Sender : SAI INTERNATIONAL SCHOOL

Name of District :- Solan Block :- Nalagarh Sub Division :- Nalagarh .

Gram Panchayat :- Manguwal Village :- Manguwal Location :- Manguwal

Source :- Borewell Habitation :- Manguwal

Date & Time of Collection :- 07-04-2026 Time :-10:16 AM


Date & Time of Receipt at Laboratory :- 07-04-2026 Time :- 10:16PM


Date & Time of Commencing :- 07-04-2026 Time - 10:16PM


A.) PHYSICAL TEST				
Sr.No.	TESTS	Desirable Limit	Permissible Limit	Actual Result
1	Colour	5	15	7
2	Odour	Agreeable	Agreeable	Agreeable
3	Taste	Agreeable	Agreeable	Agreeable
4	Turbidity	1 NTU	5 NTU	2NTU
5	TDS/ Conductivity	500 PPM	2000 PPM	270 PM
B.) CHEMICAL TESTS				
6	CALCIUM	75	200	95.45mg/l
7	PH	6.5	8.5	7.44
8	Total Alkalinity	200 mg/l	600 mg/l	195.31mg/l
9	Chlorides	250 mg/l	1000 mg/l	165.21mg/l
	Total Hardness	200 mg/l	600 mg/l	210mg/l
10				
11	Magnesium	30 mg/l	100 mg/l	40.23mg/l
C) BACTERIOLOGICAL TEST				
12	E.Coli	OMP/N	OMP/N	OMP/N

REMARKS: -

- OBSERVATIONS ARE WITHIN LIMITS.


Tested By:-
Assistant Chemist
Water Testing Lab Nalagarh


Verified By:-
Junior Engineer
JSV Sub Division Nalagarh


Authorised Signatory:-
Assistant Engineer
JSV Sub Division Nalagarh